



**CITY OF REDONDO BEACH  
PUBLIC WORKS DEPARTMENT  
ENGINEERING SERVICES DIVISION**

**ADDENDUM NO. 1**

**Date:** December 9, 2015  
**To:** All Bidders  
**From:** City Engineer  
**Subject:** **Addendum No. 1 – RBPAC East Roof Repair Project, Job No. 20720**

The following changes to the contract documents for the above subject project shall be incorporated into the plans and specifications of said project and made part thereof:

CLARIFICATIONS:

1. Re-use existing counterflashing along walls. Install 22 gauge, skirt metal counterflashing to the existing metal and fasten every 6" on center as required by roofing manufacturer. Remove and replace existing caulking above the counterflashing with new caulking.
2. No conduit or pipes rest on the new roof surface. Any conduit or pipes near the roof surface that cannot be adjusted to sit on redwood block and walkpad, shall sit on a walkpad.

Acknowledgment of this Addendum shall be executed and attached to your Bid Proposal form. Failure to do so shall result in your bid being rejected.

**CITY OF REDONDO BEACH**

By: Wisam Altowaiji  
Wisam Altowaiji, City Engineer

**ACKNOWLEDGED**

Bidder's Name: \_\_\_\_\_

Authorized Representative: \_\_\_\_\_ Date: \_\_\_\_\_